

**North Dakota State Implementation Plan  
for  
Regional Haze  
Supplement No. 2**

A Plan for Implementing the Regional Haze Program Requirements  
of  
Section 308 of 40 CFR Part 51, Subpart P – Protection of Visibility

North Dakota Department of Health  
Adopted: 12/20/12



Division of Air Quality  
Air Pollution Control Program  
North Dakota Department of Health  
918 East Divide Avenue  
Bismarck, North Dakota 58501-1947  
Telephone 701-328-5188

Terry Dwelle, M.D., M.P.H.T.M.  
State Health Officer

Terry O'Clair, P.E.  
Director

APPROVAL PAGE


North Dakota State Implementation Plan for Regional Haze  
Supplement No. 2

North Dakota Department of Health, Environmental Health Section, Division of  
Air Quality.

Approval by the following North Dakota Department of Health Management Personnel:

  
\_\_\_\_\_  
Terry L. O'Clair, P.E.  
Director  
Division of Air Quality

12/19/2012  
Date

  
\_\_\_\_\_  
L. David Glatt, P.E.  
Chief  
Environmental Health Section

12/20/12  
Date

Adopted for the North Dakota Department of Health

  
\_\_\_\_\_  
Terry L. Dwelle, M.D., M.P.H.T.M  
State Health Officer  
North Dakota Department of Health

12/20/2012  
Date

Supplement No. 2

to

North Dakota State Implementation Plan

For

Regional Haze

December 2012

North Dakota Department of Health  
Division of Air Quality  
Air Pollution Control Program  
918 E. Divide Avenue  
Bismarck, North Dakota 58501-1947

## Table of Contents

### Supplement No. 2 to North Dakota State Implementation Plan for Regional Haze

- I. Summary of Additions
- II. SIP Additions
  - A. Appendix B.2.1 - Department's Supplemental BART Determination
    - Findings of Fact
    - Supplemental Evaluation of NO<sub>x</sub> BART Determination for Coal Creek Station Units 1 and 2
  - B. Appendix C.2.1 - Great River Energy's BART Analysis
  - C. Appendix F.1.5 - Public Notice
  - D. Appendix F.3.1 - Affidavit of Publication
  - E. Appendix F.4.1 - Invoice of Publication
  - F. Appendix F.8.1 - Response to Public Comments
  - G. Appendix J.1.6 - FLM Consultation
  - H. Appendix J.3.4 - EPA Consultation

## **I. Summary of Additions**

Supplement No. 2 to the N.D. Regional Haze SIP provides additional information and analysis for the NO<sub>x</sub> BART determination for Coal Creek Station Units 1 and 2. The information includes an updated analysis by GRE dated April 5, 2012 with a technical update on June 7, 2012. GRE's analysis is added as Appendix C.2.1 of the SIP. The Department's review of GRE's analysis entitled "Supplemental Evaluation of NO<sub>x</sub> BART Determination for Coal Creek Station Units 1 and 2" and the Department's "Findings of Fact" are added to the SIP as Appendix B.2.1. Documents demonstrating the Department's consultation efforts with the Federal Land Managers and EPA are added as Appendices J.1.6 and J.3.4. Public notice documents are added as Appendices F.1.5, F.3.1 and F.4.1. The Department's Response to Public Comments is added as Appendix F.8.1

The additions to the SIP do not change the BART requirements for NO<sub>x</sub> at the Coal Creek Station. The additional information supplements the original determination made by the Department that BART is a limit of 0.17 lb/10<sup>6</sup> Btu on a 30-day rolling average basis.

The Public Notice for this SIP Supplement offered the opportunity for a public hearing. There was no request for a public hearing so none was held. Therefore, this SIP Supplement does not contain a Certification for the Public Hearing, a transcript of the hearing or a list of attendees.

## **II. SIP Additions**