



SUMMARY INFORMATION ON UNDERGROUND STORAGE TANKS

North Dakota Department of Health - Division of Waste Management
 Telephone: 701.328.5166 Fax: 701.328.5200 Web site: www.ndhealth.gov/wm
 Public Notice Rev.: 04/2008



General Information

Total Number of UST Facilities: 879 Public Record Posted Date: 10/02/2017

Total Number of USTs: 2340 Reporting Period Dates: 10/01/2016 to 09/30/2017

Summary Information For On-Site Inspections

Number of UST Facilities Inspected: 304

Percent Compliance: 86.27%

Summary Information For Release

Number of Confirmed UST Releases: 5

Summary Information For Release Sources and Causes

Source			Cause													
			Spill		Overfill		Phy/Mech Damage		Corrosion		Install Problem		Other		Unknown	
#	%		#	%	#	%	#	%	#	%	#	%	#	%	#	%
Tank	7	41.2	0	0.0	0	0.0	0	0.0	3	50.0	0	0.0	0	0.0	4	44.4
Piping	9	52.9	2	100.0	0	0.0	0	0.0	3	50.0	0	0.0	0	0.0	4	44.4
Dispenser	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
STP	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
Delivery Problem	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
Other	1	5.9	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0	1	11.1
Totals	17	100.0	2	100.0	0	0.0	0	0.0	6	100.0	0	0.0	0	0.0	9	100.0

= Number of releases

% = Percent of total number of Source

Note: Release, sources and causes information are based on USTs as defined in NDAC Section 33-24-08-40. Source and cause data is collected from information provided through release reporting as required in NDAC Section 33-24-08-40. Site specific UST information on compliance and releases can be obtained upon request.