

**North Dakota Regional Haze  
EPA-R08-OAR-2010-0406**

Boilers Equipped with SNCR and that are Controlling NOx to under 0.17 lb/MMBtu  
(from 2010 annual Title IV data)

STATE	FACILITY_NAME	Unique ID	OP_YEAR	NOX_RATE	OWNER	UNIT TYPE	PRIMARY FUEL	NOX_CONTROL_INFO	CAPACITY MMBtu/hr
MA	Salem Harbor	1626_1	2010	0.158	Dominion Energy Salem Harbor, LLC (Owner/Operator)	Dry bottom wall-fired boiler	Bit	Selective Non-catalytic Reduction Low NOx Burner Technology (Dry Bottom only)	954
MA	Salem Harbor	1626_2	2010	0.1634	Dominion Energy Salem Harbor, LLC (Owner/Operator)	Dry bottom wall-fired boiler	Bit	Selective Non-catalytic Reduction Low NOx Burner Technology (Dry Bottom only)	966
MA	Somerset	1613_8	2010	0.1263	Somerset Power, LLC (Owner/Operator)	Tangentially-fired	Bit	Selective Non-catalytic Reduction Combustion Modification/Fuel Reburning	1186
MN	Taconite Harbor Energy Center	10075_1	2010	0.1393	Minnesota Power, Inc. (Owner/Operator)	Tangentially-fired	Sub	Overfire Air Selective Non-catalytic Reduction	745
MN	Taconite Harbor Energy Center	10075_2	2010	0.1458	Minnesota Power, Inc. (Owner/Operator)	Tangentially-fired	Sub	Overfire Air Selective Non-catalytic Reduction	745
<i>TX</i>	<i>Big Brown</i>	<i>3497_1</i>	<i>2010</i>	<i>0.1376</i>	<i>Big Brown Power Company LLC (Owner) Luminant Generation Company LLC (Operator)</i>	<i>Tangentially-fired</i>	<i>Lignite</i>	<i>Low NOx Burner Technology w/ Separated OFA Selective Non-catalytic Reduction</i>	<i>7901</i>

Boilers Equipped with SNCR and that are Controlling NOx to under 0.17 lb/MMBtu  
(from 2010 annual Title IV data)

STATE	FACILITY_NAME	Unique ID	OP_YEAR	NOX_RATE	OWNER	UNIT TYPE	PRIMARY FUEL	NOX_CONTROL_INFO	CAPACITY MMBtu/hr
TX	Big Brown	3497_2	2010	0.1437	Big Brown Power Company LLC (Owner) Luminant Generation Company LLC (Operator)	Tangentially-fired	Lignite	Low NOx Burner Technology w/ Separated OFA Selective Non-catalytic Reduction	8132
<i>TX</i>	<i>Monticello</i>	<i>6147_1</i>	<i>2010</i>	<i>0.1294</i>	<i>Luminant Generation Company LLC (Owner/Operator)</i>	<i>Tangentially-fired</i>	<i>Lignite</i>	<i>Low NOx Burner Technology w/ Separated OFA Selective Non-catalytic Reduction</i>	<i>7382</i>
<i>TX</i>	<i>Monticello</i>	<i>6147_2</i>	<i>2010</i>	<i>0.1315</i>	<i>Luminant Generation Company LLC (Owner/Operator)</i>	<i>Tangentially-fired</i>	<i>Lignite</i>	<i>Low NOx Burner Technology w/ Separated OFA Selective Non-catalytic Reduction</i>	<i>7055</i>
WI	Edgewater (4050)	4050_4	2010	0.1464	Wisconsin Public Service Corporation (Owner) Wisconsin Power & Light Company (Owner/Operator)	Cyclone boiler	Sub	Overfire Air Other Selective Non-catalytic Reduction	4629

Note: Facilities listed in red italics are referenced as examples in EPA's final rule for North Dakota regional haze.